



Monroe Energy, LLC 4101 Post Road Trainer, PA 19061 (610) 364-8000

October 10, 2018

Via FedEx

James Rebarchak Regional Air Program Manager PA Department of Environmental Protection 2 East Main Street Norristown, PA 19401

RECEIVED

OCT 0 4 2018

Subject:

Benzene Waste Operations NESHAPS

Quarterly Report: July 1, 2018 through September 30, 2018

EPA ID No. PAR 000015768

Air Protection Division

Dear Mr. Rebarchak:

Monroe Energy, LLC, Trainer Refinery, submits this letter to fulfill the quarterly reporting requirements pursuant to 40 CFR Part 61, Subpart FF, §61.357(d).

During this reporting period, the Crude Oil Desalter Brine Treatment Unit (BTU) was monitored as required by 40 CFR §61.354(a)(1). Monthly samples were collected in July, August, and September. Measured benzene concentration in the BTU effluent remained less than 10 ppmw (10 mg/L) during the reporting period.

In addition to the above, all other required monitoring and inspections have been completed in accordance with the requirements of the aforementioned section.

Based on the information and belief formed after reasonable inquiry, I certify that the statements and information contained in this report are true, accurate, and complete.

If you have any questions about this report, please call Stephani Ski Szymanski, Environmental Engineer, at (610) 364-8073.

Sincerely,

Michael Capone Operations Leader

Cc: Office of Air Enforcement & Compliance Assistance

U.S. EPA, Region 3 Mail Code 3AP20 1650 Arch Street

Philadelphia, PA 19103-2029

Via FedEx